

ADDENDUM TO DEP SEPTIC INSPECTION REPORT

Inspection Location _____ Map & Parcel _____

- | | | | | |
|----|--------------------------------------------------|-------|----------------------------|-------|
| 1. | <u>Residential Property</u> | | <u>Commercial Property</u> | |
| | Bedrooms <i>(incl. den, sewing room, office)</i> | _____ | Employees | _____ |
| | Family Rooms | _____ | Toilets | _____ |
| | Living Rooms | _____ | Rooms with Bath | _____ |
| | Bathrooms | _____ | Square Feet | _____ |
| | Dining Rooms | _____ | | |
| | Kitchens | _____ | | |
| | Other: _____ | _____ | | |
| | Total: _____ | _____ | | |

2. Floor Plan: Show all floors including basement:

[illegible]

3. Is the septic system, as inspected, in full compliance with either the 1978 (__) or 1995 (__) Title 5 code? Yes ____ No ____
If not, list deficiencies _____
4. Is the system in the Zone II (Water Resource Protection District)? Lot size: _____ Yes ____ No ____


TOWN OF HARWICH
ADDENDUM TO DEP SEPTIC INSPECTION REPORT

Inspection Location _____ Map & Parcel _____

5. Is there a 4' separation (1978 code) or a 5' separation (1995 code) Yes _____ No _____
between the bottom of the S.A.S. and adjusted groundwater?

Indicate how groundwater was verified:

USGS Maps _____ Engineers letter on file _____ Hand auger _____
& Groundwater (post 1995 installation)
Contour Map



6. Town Water (___) or Private Well (___).
Distance from nearest septic system component: _____
7. Wetlands or surface water within 100' of septic system? Yes _____ No _____
Distance from nearest septic system component: _____
8. Type of pipe used in system
PVC _____ Orangeberg _____ Other _____
9. Sanitary tees or baffles in place (Yes – No – N/A?)
 Septic tank inlet _____
 Septic tank outlet _____
 Pump chamber inlet _____
 D-box inlet if pumped system _____
 Grease trap inlet _____
 Grease trap outlet _____
 Risers – 1978 code within 12 inches of grade on septic tank _____
 Risers – 1995 code within 6 inches of grade on all components _____
 One inspection port on S.A.S. (1995 code) _____